

**Mayo County Council**  
**Rural Water Section**  
**Current Boil Water Notices (29/05/2017)**

<b>GWS NAME</b>	<b>Location (Municiple District)</b>	<b>Commencement date</b>	<b>Water Quality Failure</b>	<b>Proposed action</b>
<b>Cushin GWS</b>	Castlebar-Westport rd (Castlebar & West Mayo Municiple Districts)		Recurring Water quality Failures	Proposed GWS upgrade and connection to Lough Mask RWSS:- Construction due to be completed in Q3 2017.
<b>Ayle GWS</b>	Castlebar-Westport rd (Castlebar & West Mayo Municiple Districts)	04/11/2015	Recurring Water quality Failures	
<b>Sraheens GWS</b>	Foxford (Ballina Municiple District)	12/11/2015	No chlorine in Network	Chlorine levels raised in Treatment Plant, negotiations ongoing with DBO operator to take over rising mains and remote reservoir and install chlorine boosting.
<b>Knockinakell GWS</b>	Claremorris (Claremorris Municiple District)	11/12/2015	16 Coliforms 1 E.coli	Following site Audit HSE sampled and recommended BWN as the GWS has no form of treatment / disinfection. Investigation is underway to identify a new source
<b>Cornboy GWS</b>	Erris (West Mayo Municiple District)	25/08/2016	176 Coliforms	HSE Sampled scheme, twice, both times failed and recommended BWN. Scheme due to scour and disinfect the scheme.
<b>Private Well at Ballymachugh,</b>	Ballycastle (Ballina Municiple District)	18/08/2016	5 coliforms	HSE Sampled well, failed and recommended BWN. Owner identified 8 people using well.
<b>Robeen GWS</b>	Claremorris (Claremorris Municiple District)	03/10/2016	1 cryptosporidium ocysts	Further investigation into improvement in source
<b>Glencorrib Group Water Scheme</b>	Glencorrib (Claremorris Municiple District)	09/06/2017	74 Coliforms 11 E. coli	Treatment plant currently been upgraded, work expected to be completed within 4 weeks
<b>Drumsheen Newtown Group Water Scheme</b>	Bunniconlon (Ballina Municiple District)	09/06/2017	36 Coliforms 5 E. coli	Investigation underway, possible permanent solution is to connect into the adjacent Ballina RWSS