

Notification of the Failure to Meet the Parametric Values in Part 1 of the Schedule of the European Communities (Drinking Water) Regulations, 2007 (S.I. No 278 of 2007) in Accordance with Regulation 9(1) or 10(2)

Sanitary Authority	Mayo County Council
Water Supply Zone	Cong PWS
Water Supply Zone Code	2200PUB1012
Estimated Population Affected	700
Parameter	THM
Result¹	128.44 ug/l
Date of Failure	18/08/2011
Notification under Regulation (please tick)	9(1) No
	10(2) Yes
Have the HSE been consulted?	Yes Noel Mahon A/PEHO
What advice has been provided by the HSE	Check mains to determine if the section of main has low usage and is low point and scour
Likely Cause and Duration of Failure	High organic content of water.
Has this parameter exceeded the Parametric Value in this Supply in the past 12 months (if so give details)?	Yes 101 on 09/05/11 105 on 14/06/11
Immediate Action Taken to Inform/Protect Consumers	Mains scouring and re-sampling by HSE It is not possible to reduce cl2 residuals further.
Immediate Corrective Action Taken	1. Mains scouring

Notified by: Michael Mc Dermott

Date: 01/09/2011

¹ If the failure was a microbiological failure please indicate the residual chlorine levels at the time.

